

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE**

No. 896

Dated: 25/7/24

It is certified that an inspection team headed by....**Rajvir Singh J.E** .... (Name of Officers with Designation) from **Water Supply and Sanitation** (Name of Department/ Office) inspected the **AKAL ACADEMY THEH KALANDHAR**, Post Office Behak Khas, District Fazilka, Pin Code 152123 (Name & Address of the school) on **23-07-2024** (date of inspection ) and found that the **AKAL ACADEMY THEH KALANDHAR** (Name of School) has safe drinking Facilities for students and staff of the institution and is maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State / U.T. Govt.

The above is valid for a period of.....**1 Year**...

Signature with Seal:


ਗੁਪ ਸੰਤੋਲ ਇੰਜੀਨੀਅਰ  
ਵ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ  
ਭਾਗ ਮੰਤਰਾਲੇ, ਫਾਜ਼ਿਲਕਾ

ਗੁਪ ਸੰਤੋਲ ਨੰ: 1-ਫਾਜ਼ਿਲਕਾ

Name : **Abhijeet Singh**Designation : **Sub Division Engineer**

Name &amp; Address of the Office / Department

Water Supply and Sanitation,  
Sub Division No. 1, Fazilka, I.T.I,  
Near Malout Chownk, Fazilka

  
Manager  
Akai Academy  
Theh Kalandhar (FZ)

To  
Principal,  
Akai Academy Theh Kalandhar,  
Post Office: Behak Khas,  
Tehsil- Fazilka, 152123, PB

(Name &amp; Address of the Institution)



\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a

# DISTRICT WATER TESTING LABORATORY, FAZILKA

Village Panchawali, Fazilka  
dwtlfazilka@gmail.com


## TEST REPORT

Name & Address of Customer : <b>AKAL ACADEMY THEH KALANDHER</b> Fazilka		Customer Reference No.	No : AA/TK/2024/25 Dated : 11/06/2024
		Sample Submitted by	Sukhjinder Singh
		Date of Sample Receipt	18/06/2024
		Analysis Starting Date	20/06/2024
		Analysis completion Date	21/06/2024
Discipline : Chemical Testing		Group: Water	
ULR No.:		Sample Type :	Water
Test Report No.:	DWTL/FZK/2425/00033	Date of Issue :	27/06/2024
Registration no.:	DWTL/FZK/REG2425/00087	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	AKAL ACADEMY THEH KALANDHER Fazilka / NA
Village :	Theh Qulander	Habitation :	Theh Qulander
Block:	Fazilka	District :	Fazilka
Latitude :	Not Mentioned	Longitude:	Not Mentioned


Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.09@23°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	129	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO3)	56	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO3)	48	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
9	Calcium(Ca)	4	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium(Mg)	8	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11.	Chloride(Cl)	26	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS= Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

  
Manager  
Akai Academy  
Theh Kalander (F.Z.)



Reviewed and Approved By  


Ashish Kumar  
Sr. Chemist  
Authorized Signatory  
For, District Water Testing Laboratory  
Fazilka

----- End of the Test Report -----