

# PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO. 446

DATE: 22/4/25

It is certified that an inspection team headed by Mr. Joginder Singh J.E....(Name of officers with Designation) from Water Supply and Sanitation(Name of Department/ Officer) inspected the AKAL ACADEMY THEH KALANDHAR, Post Office Behak Khas, District Fazilka, Pin Code 152123(Name & Address of the School) on 17-04-2025(date of inspection) and found that the AKAL ACADEMY THEH KALANDHAR(Name of School) has safe drinking Facilities for students and staff of the institution and is maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of .....1 Years...



Signature with Seal Sub Divisional Engineer  
Water Supply & Sanitation  
Sub Division No. 1, Fazilka

Name : Abhijeet Singh  
Designation: SDE

Name & Address of the Office/ Department  
Water Supply and Sanitation,  
Sub Division No. 1, Fazilka, ITI,  
Near Malout Chownk, Fazilka

To  
Principal,  
Akal Academy Theh Kalandhar  
Post Office: Behak Khas,  
Tehsil- Fazilka, 152123, PB

(Name & Address of the Institution)

Manager  
Akal Academy  
Theh Kalandhar (FZK)

The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificates a pdf



# DISTRICT WATER TESTING LABORATORY, FAZILKA

Village Panchawali, Fazilka  
dwtlfazilka@gmail.com



TC-14083

## TEST REPORT

Name & Address of Customer : Akai Academy Theh Kalander (Fazilka)		Customer Reference No.	No : AATK2025/26/02 Dated : 07/04/2025
		Sample Submitted by	Pardeep Kumar
		Date of Sample Receipt	07/04/2025
		Analysis Starting Date	07/04/2025
		Analysis completion Date	09/04/2025
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC140632500000175F	Sample Type :	Water
Test Report No.:	DWTL/FZK/2526/00014	Date of Issue :	11/04/2025
Registration no.:	DWTL/FZK/REG2526/00014	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Akai Academy Theh Kalander (Fazilka) RO Treated Water / NA
Village :	Theh Qulander	Habitation :	Theh Qulander
Block:	Fazilka	District :	Fazilka
Latitude :	Not Mentioned	Longitude:	Not Mentioned


Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.13@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	133	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO <sub>3</sub> )	52	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO <sub>3</sub> )	48	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	3	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	5	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	24	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

- The results apply to the sample as received only.
- The sample will be destroyed after retention time unless otherwise specified specially.
- This report is not to be reproduce wholly or in part and can't be used be as evidence in court of law.
- Abbreviation used (TDS = Total Dissolved Solids, mg/l) = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
- \* Value not available or test not performed for this parameter.
- Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%


  
  
 Principal  
 Affiliation No.  
 1631362

Reviewed and Approved By



Ms.Sushma bala  
Chemist/Analyst  
Authorized Signatory  
For, District water Testing Laboratory  
Fazilka

End of the Test Report

  
 Manager  
 Akai Academy  
 Theh Kalander (FZK)