

DISTRICT WATER TESTING LABORATORY, FAZILKA

Village Panchawall, Fazilka
dwtfazilka@gmail.com



TEST REPORT

Name & Address of Customer : Akai Academy Theh Kalandhar (Fazilka) Akai Academy Theh Kalandhar (Fazilka)	Customer Reference No.	No : AA/TK/2023/24 Dated : 24/04/2023
	Sample Submitted by	Gurjeet Kour
	Date of Sample Receipt	04/05/2023
	Analysis Starting Date	04/05/2023
	Analysis completion Date	06/05/2023

Discipline : Chemical Testing	Group: Water	
ULR No.: TC10093230000307F	Sample Type :	Water
Test Report No.: DWTL/FZK/2324/00065	Date of Issue :	09/05/2023
Registration no.: DWTL/FZK/REG2324/00077	Condition of Sample :	Unsealed
Collection Point: Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source: Not Mentioned(Not Mentioned)	Location/Depth :	Akai Academy Theh Kalandhar (Fazilka) / NA
Village : Not Mentioned	Habitation :	Not Mentioned
Block: Fazilka	District :	Fazilka
Latitude : Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.8	6.5-8.5	No Relaxation		IS 3025 (Part 11-1993) Electrometric Method
2	Colour	1	5	15	CU	IS 3025 (Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable		IS 3025 (Part 5 - 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable		IS 3025 (Part 8 - 1984) (RA 2017)
5	TDS	112	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
7	Alkalinity	76	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
8	Hardness	40	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
9	Calcium	14	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	1	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
11	Chloride	34	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduced wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NI = Not tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * value not available or test not performed for this parameter
6. Temperature condition limit: 25±5°C and Humidity condition limit: 50 ± 20%

Mr. Pardeep kumar
Quality Manager
Authorized Signatory
For, District water Testing Laboratory, Fazilka

----- End of the Test Report -----

Page No : 1/1

Manager
Akai Academy
Theh Kalandhar (FZK)

Principal
Akai Academy
Theh Kalandhar (Fzk)


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.777

Dated: 17-08-2023

It is certified that an inspection team headed byRajvir Singh J.E..... (Name of Officers with designation) from Water Supply and Sanitation (Name of Department/ Office) inspected the AKAL ACADEMY THEH KALANDHAR (Name & Address of the school) on 17-08-2023 (date of inspection) and found that the AKAL ACADEMY THEH KALANDHAR, Fazilka (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of.....1 Year.....

Signature with Seal: Name : Abhijeet SinghDesignation : Sub division EngineerName & Address of the Office / Department: Water supply and Sanitation, Subdiv No. 1, Fazilka, T.T. 1, Near Malout Chowk, Fazilka


To

Principal, Akal Academy Theh
kalandhar, PO- Behak Khas
Tehsil-Fazilka, 152123, PB

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.


Manager
Akal Academy
Theh Kalander (Fzk)


Principal
Akal Academy
Theh Kalander (Fzk)